



Certificate of Compliance

Certificate: 1287592

Master Contract: 180161

Project: 2669225

Date Issued: November 5, 2013

Issued to: Relpol S.A.

Ul 11 Listopada 37

Zary, 68-200

Poland

Attention: Tomasz Ochocki

The products listed below are eligible to bear the CSA Mark shown



Areez Lalani

Issued by: Areez Lalani

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Relays R2 and R2N with suffixes, 2-pole, rated 250 VAC, 10 A, Resistive; 150 VAC, 12A, Resistive; Coil rated 6 through 220 VDC, 6 through 240 VAC, 50/60 Hz;

Relays R3 and R3N with suffixes, 3-pole, rated 250 VAC, 6 A, Resistive; 150 VAC, 10A, Resistive; Coil rated 6 through 220 VDC, 6 through 240 VAC, 50/60 Hz;

Relays RM84 with suffixes, 2-pole, rated 250 VAC, 8 A, Resistive; Coil rated 3 through 110 VDC, 24 through 240 VAC, 50/60 Hz;

Relays RM85 with suffixes, 1-pole, rated 250 VAC, 16 A, Resistive; 24V DC, 10A, Resistive; Coil rated 3 through 110 VDC, 24 through 240 VAC, 50/60Hz;

Relays RM85 with suffixes, sensitive version, 1-pole, rated 250 VAC, 10 A, Resistive; 24VDC, 10A, Resistive; Coil rated 6 through 24 VDC

Relays RM87 with suffixes, 1-pole, rated 250 VAC, 12 A, Resistive; Coil rated 3 through 110 VDC, 24 through 240 VAC, 50/60 Hz;

Note: Open type devices are certified, as components, for use only in other Certified equipment where the suitability of the combination is to be determined by CSA International.



Certificate: 1287592

Master Contract: 180161

Project: 2669225

Date Issued: November 5, 2013

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14 - Industrial Control Equipment