



Certificate of Compliance

Certificate: 1218640

Master Contract: 180161

Project: 2659152

Date Issued: November 5, 2013

Issued to: Relpol S.A.

Ul 11 Listopada 37

Zary, 68-200

Poland

Attention: Tomasz Ochocki

The products listed below are eligible to bear the CSA Mark shown



Areez Lalani

Issued by: Areez Lalani

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Relays R4 and R4N with suffixes, 4-pole, rated 250 VAC, 6 A, Res., Same Polarity, Coil rated 5 through 220 VDC, 6 through 240 VAC

Relays RUC rated 250 VAC, 3 pole, 10 A, Res., and 2 pole, 15 A, Res., 2-pole, 15a, 150V ac, General Purpose, single phase; 2-pole, 10A, 250V ac, General Purpose, single phase; 2-pole, 10A, 28V dc, resistive; 2-pole, 1/3hp, 120V ac, single phase; 2-pole, 1/2hp, 240V ac, single phase; 2-pole, B300. 3-pole, 10A, 250V ac, General Purpose, single phase; 3-pole, 10A, 28V dc, resistive; 3-pole, 1/3hp, 120V ac, single phase (7.2 FLA); 3-pole, 1/2 hp, 240V ac, single phase (4.9 FLA); 3-pole, 1/2 hp, 240V ac, three-phase (2.2 FLA); 3-pole, B300, coil rated 6 through 220 VDC, 6 thorough 240 VAC

Relay Sockets SU4 and G4, rated 250 V, 6 A, Same Polarity.

Notes:

Open type devices are certified, as components, for use only in other Certified equipment where the suitability of the combination is to be determined by CSA International.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 14 - Industrial Control Equipment