



Certificate of Compliance

Certificate: 1308941 (LR86957)

Master Contract: 180161

Project: 1793301

Date Issued: 2006/06/28

Issued to: Relpol S.A.

Ul 11 Listopada 37

Zary, 68-200

Poland

Attention: Mr. Tomas Ochocki

The products listed below are eligible to bear the CSA Mark shown



Issued by: Ricardo Sanchez

Authorized by: Nick Alfano, Operations Manager

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Relay sockets, open types , models and ratings as below:

Model - No.Poles - Amps - Voltage - Restrictions

GZT2 --- 2p ----- 12A ----- 300Vac

GZT3 --- 3p ----- 10A ----- 300Vac - Maximum 20A multipole

GZT4 --- 4p ----- 6A ----- 300Vac - Maximum 20A multipole

GZT80 -- 1p ----- 12A ----- 300Vac



Certificate: 1308941 (LR86957)

Master Contract: 180161

Project: 1793301

Date Issued: 2006/06/28

GZT80 -- 2p ----- 8A ----- 300Vac

GZT92 -- 1p ----- 12A ----- 300Vac

GZM2 --- 2p ----- 12A ----- 300Vac - Maximum 20A multipole

GZM3 --- 3p ----- 10A ----- 300Vac - Maximum 20A multipole

GZM4 --- 4p ----- 6A ----- 300Vac - Maximum 20A multipole, Same Polarity

GZM80 -- 1p ----- 10A ----- 300Vac

GZM80 -- 2p ----- 8A ----- 300Vac

GZM92 -- 1p ----- 12A --- 300Vac

Note: Open type devices are Certified as component parts of other equipment where the suitability of the combination is to be determined by the CSA International.

APPLICABLE REQUIREMENTS

CSA - C22.2 No. 14 Industrial Control Equipment